



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2002720

Connecting terminal board

Type designation: KP 425/M10, KP 525/M10

Certificate holder: AB Fingal Johnsson o. Söner
Box 525
331 25 Värnamo
Sweden

The product complies with the standard(s): IEC 61545:1996

Date of expiry: 25 November, 2025

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 25 November, 2020

Henrik Wikström

APPENDIX:

Reference No. SE-S-2002720

Technical Data:

Type designation KP 425/M10, KP 525/M10
Rated voltage (V) 450V
Conductor area Aluminum 16 – 25 mm², Copper 1.5 – 25 mm²
Number of terminals 4 / 5
Trademark FI-JO
Test Report 2025967STO-001
Product information Four respectively five terminals in row placed in an insulating plastic box without fixing means, rigid and flexible conductors, for built-in purposes.

Al-conductors torque: 10 Nm

Cu-conductors 10 – 25 mm² torque: 10 Nm.

Cu-conductors 1.5 – 6 mm² torque: 4 Nm.

Additional tests according EN 60 998-2-1: Resistance to ageing, to Humidity conditions, Insulation resistance and resistance to electric strength, Resistance to heat, Creepage distance and clearance and Resistance of insulating material to tracking.

Manufacturing Sites:

AB Fingal Johnsson o Söner
Storgatan 45
330 21 Reftele
Sweden

This certificate replaces previously issued ref. no 1303582, dated 30 November 2015.
A new certificate has been issued due to renewal testing.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 25 November, 2020

Henrik Wikström